


CNM-3M CONDENSATE NEUTRALIZATION MEDIA INSTALLATION, OPERATION AND MAINTENANCE INSTRUCTIONS

Installation Instructions

NOTE - Check with your local water authority for regulations regarding discharge of treated condensate to the drain or sewer system.

 **WARNING:** This product can expose you to Silica, crystalline (airborne particles of respirable size) which is known in the state of California to cause cancer. For more information go to www.P65Warnings.ca.gov

CNT-Series – Remove the old neutralizing media and rinse the tank clean. Pour the grey rock chips into the tank. Then empty the smaller bag of white media on top of this and mix slightly.

Operation

The appliance condensate will flow through the neutralizing media, raising the pH of the condensate to a level that will help prevent corrosion of the domestic drain and the public sewer system.

Maintenance

Monitor the level of the neutralization media in the tank periodically. Check the pH level at the outlet of the neutralizing kit periodically and use a suitable pH test strip paper. The neutralizing media should be replaced when the pH level drops below the minimum level of the local water authority. For replacement media contact your local DiversiTech distributor.